

## State Water Resources Control Board

October 12, 2016

(Via email and Certified Mail)

**CERTIFIED MAIL**

**NO. 7015 1520 0001 8017 0705**

Ms. Laura Ballesteros  
Development Specialist  
Riverside County Economic  
Development Agency  
3133 Mission Inn Avenue  
Riverside, CA 92507  
[lballesteros@rivcoeda.org](mailto:lballesteros@rivcoeda.org)

**SUBJECT: NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEM  
LOCATED AT COUNTY OF RIVERSIDE SOUTHWEST JUSTICE DETENTION,  
30755 AULD ROAD #1307, MURRIETA**

Dear Ms. Ballesteros:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the USTs at your facility on September 21, 2016, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and title 23, California Code of Regulations (CCR), chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	<b>Failure to Monitor Product Piping –</b> The test boots were on both the supply and return lines preventing the detection of a leak at the earliest opportunity. The test boots need to be pulled back from the secondary containment or the Schrader valve needs to be removed and pointed downward between three and nine o' clock position.	Diesel	September 21, 2016	Ongoing	H&SC 25291(b); 23 CCR 2630(d)
2	<b>Failure to Update Tank Information (A &amp; B Forms) –</b> The tank form in CERS states that the tank is a conventional suction system. However, a turbine was present, making it a pressurized system.	Diesel	September 21, 2016	Ongoing	H&SC 25286(a); 23 CCR 2711(a)

**You are directed to correct the ongoing violations and submit compliance documentation to the State Water Board and County of Riverside County Department of Environmental Health within sixty (60) days from the date of this letter. Have your Designated Operator make specific notations in the next monthly designated operator report indicating the ongoing violations have been corrected. The monthly designated operator report and any associated photos must be submitted as proof of compliance.**

Please send all compliance documentation to the following:

**State Water Board**

Mr. Joseph Lovesee  
UST Enforcement Unit  
Office of Enforcement  
State Water Resources Control Board  
1001 I Street  
Sacramento, California 95814  
[joseph.lovesee@waterboards.ca.gov](mailto:joseph.lovesee@waterboards.ca.gov)

**Local CUPA**

Mr. Jeff Johnson  
Program Chief  
Riverside County Department of  
Environmental Health  
4065 County Circle Drive  
Riverside CA, 92503  
[jeffjohnson@rivcocha.org](mailto:jeffjohnson@rivcocha.org)

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me at (916) 341-5551, or by email at [amantha.henkel@waterboards.ca.gov](mailto:amantha.henkel@waterboards.ca.gov).

Sincerely,



Amantha Henkel  
Senior Environmental Scientist  
UST Enforcement Unit  
**Office of Enforcement**

cc: *(via email only)*

Mr. Jeff Johnson  
Program Chief  
Riverside County Department of  
Environmental Health  
[jeffjohnson@rivcocha.org](mailto:jeffjohnson@rivcocha.org)

Mr. Manny Moran  
Building Engineer  
Riverside County EDA  
[mmoran@rivcoeda.org](mailto:mmoran@rivcoeda.org)